

DAHLMAN PUMP & SUPPLY

PUMPS - SALES and SERVICE
WELL DRILLING - TESTING & CLEANING
BURLINGTON, WASHINGTON

June 12, 1963

Elliott, Lee, Carney and Thomas
Attorneys At Law
555 Dexter Horton Building
Seattle 4, Washington

Dear Mr. Carney:

We have concluded the test as per your letter of April 26, 1963, on the Manson and Osborn well (Bonchcombers) and have forwarded a sample of the water to the State Health Department. A copy of their report will be forwarded to you.

Our test showed that this well will furnish 100 gallons per minute under continuous pumping, and that the water is of good quality. The well is 305 feet deep, this includes 5 feet of well screen; static water level is 267 feet. The chemical analysis of our test is as follows.

Iron content very low; less than 0.6 parts iron per million parts water.

Hardness--fair; 9 grains per gallon which is softer than the average Whidbey Island water.

pH or Acidity slightly below neutral which is 0.7 on the scale with the sample reading 6.8 which indicates no corrosion of pipes or hot water tanks.


I am enclosing a copy of Island County Roadbed Standard, which will be of assistance to designing engineers.

The Health Department needs the legal description of this property and the exact well location for their records. If you could send me this I will forward it to them.

We have a gallon of the water which we saved at time of test. If you want this water you may pick it up at anytime.

Thanking you for this opportunity of being able to serve you and hoping that we can be of further assistance to you in the future.

Yours truly,
Dahlman Pump & Supply



C. L. Dahlman

Enc. 2
CLD/WF

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.